

ENGINEERING GROUP, LCMG  
NBP HEAD OFFICE KARACHI

MINUTES OF PRE-BID MEETING

**TENDER TITLE:** Procurement of Wall Mounted Split Air-conditioners 1.0 Ton 1.5 Ton & 2.0 Ton Capacity Inverter Type with Ancillary Services for NBP Branches/ Offices Located at Different Cities Throughout Pakistan

**NBP TENDER ID:** NT-06/13/2024-9

**PPRA TENDER NO:** TS541874E

**HELD ON:** June, 27 2024 at 11:30 am, NBP Head Office Building, Karachi

**PARTICIPANTS:**


- |                         |  |
|-------------------------|--|
| 1. Zubair Ali Malik     | Engineering Group, NBP                   |
| 2. Mr. Javed Akhter     | Engineering Group, NBP                   |
| 3. Mr. Abid             | M/s. Vorson (Pvt) Ltd                    |
| 4. Mr. Govind Khatri    | M/s. Eurocon Air Conditioning (Pvt) Ltd. |
| 5. Mr Shadan Jamil Khan | M/s. Bismillah Electronics.              |


The representatives of the prospective bidders were asked to share their queries with respect to any of the instructions, terms & conditions, BOQ item etc. as mentioned in the bidding documents for necessary clarifications.

The details of queries and responses are as under:

- The representative of one of the bidders; enquired about the T3 compressor and EER.  
It was clarified that due to NBP Branches located at remote areas and the climate of those areas is very hot that's why we required T3 compressor, further minimum Electric Efficiency Ratio(EER) is required 3 as mentioned in bidding documents
- The representative of one of the bidders seek clarification regarding execution of works and mode of payment.  
It was clarified that total period of execution work is 06 months, after completion of Tender requirement and issuing of work order NBP will provide the list of locations for supply and installation of ACs in phase-wise and payment will be made phase-wise after submission of acknowledgement in bank Dead Stock (Annexure-A) and satisfactory completion certificate from bank official. Furthermore, it is also clarified that in any location if there is need for replacement of ACs the dismantling of existing ACs will be responsibility of the bidders, and if extra copper pipping with control wire is required at any location of NBP the payment will be made as per actual work done at site.
- One of the bidder asked for Ac colors.  
It was informed that white color Ac will be required with uniformity.

The meeting concluded with vote of thanks to all the participating bidders.

  
Zubair Ali Malik  
Wing Head Engineering South(South)

  
Javed Akhter  
VP/Head-Mechanical