### (ORIGINAL SET) FOR

### **OPERATION AND MAINTENANCE SERVICES**

#### FOR HVAC PLANT / SYSTEM INSTALLED AT NBP G-5/1 BUILDING ISLAMABAD

"Original set must be submitted with a duplicate copy"

DOWNLOADED BY.

]	Name of Contractor/ Firm:
]	Mailing Address:
Nam	e of Authorized Contact Person:
Pern	anent Address & Contact Number:
•••••	•••••••••••••••••••••••••••••••••••••••
Sole	Proprietor / CEO etc. Name:
Cont	act Number:

# OPERATION AND MAINTENANCE OF HVAC PLANT / SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP, G-5/I BUILDING, ISLAMABAD

#### **TABLE OF CONTENTS**

Sr. No.	Description	Page No.
1.	Title Page	01
2.	Table of Contents	02
3.	Invitation for Bid	03
4.	Summary	04
5.	Bid Form	05
6.	Bidding Documents (Instruction to Bidder / Bidding Data / Contract	
	Data).	06
7.	General Terms and Conditions	07-08
8.	Schedule No.1 (Scope of Work)	00.12
_	Schedule No.2 (Staff Strength)	09-12
9.	Bill of Quantities	13-14

#### **INVITATION FOR BID**

## OPERATION AND MAINTENANCE SERVICES FOR HVAC PLANT/SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP G-5/1 BUILDING, ISLAMABAD.

National Bank of Pakistan, the leading Commercial Bank of the Country invites sealed bids for the procurements of services from HVAC Operation and maintenance firms / vendors for aforesaid works with an active status on FBR Active Taxpayer List and Provincial Revenue Board and have vast experience of Operation & maintenance of HVAC plant/system may download tender documents. The Contract will be initially for One Year, which can be extended further with mutual consent. Eligibility criteria for bidding document consists of the following.

- 1. A bidder should have a valid registration in **Pakistan Engineering Council** in financial category **C-6** or above along with **ME-01** specialties on bidding data.
- 2. Only firms who have successfully completed at least **03nos**. HVAC operation & maintenance contracts of similar nature of works (at least one year each) during last five years are eligible to bid.
- 3. An affidavit on e-stamp paper of Rs.100/- for undertaking that the firm have never been indulged in any litigation and have never been blacklisted by any department/organization.
- 4. Past performance of the firms / vendor who have previously worked with NBP shall also be considered while issuing the bidding document.

For Interested bidders: <u>Single Stage-One Envelope Bidding Documents as per PPRA Rule 36 (a)</u> containing details of bid, detailed terms and conditions, method of procurement, procedure for submission of bids, bid security, bid validity, opening of bid, evaluation criteria, clarification / rejection of bids, performance guarantee etc., have been made available at NBP web site "<a href="https://www.nbp.com.pk/TENDER">https://www.nbp.com.pk/TENDER</a>" which can be downloaded by interested contractors/ firms till business hours and within working days up till 27-11-2023.

All the interested bidders, who wish to participate in the bidding, must submit the documentary proof of above-mentioned eligibility criteria in the office "Engineering Wing (North), National Bank of Pakistan, G-5/1 Building, Islamabad. Ph. +92-51-9203117" for verification on or before 28/11/2023. In case of non-compliance/ineligibility, the contractor/firm will not be allowed to participate in the bidding process.

The bids, prepared in accordance with the instructions in the Bidding Documents along with Rs.45,000/- Bid security in shape of Pay order in the name of '' Wing Head (North), National Bank of Pakistan'' must reach in the office of:

"Wing Head, Engineering Wing (North), National Bank of Pakistan, G-5/1 Building, Islamabad. Ph. +92-51-9203117"

on or before 14:30 Hours on 30-11-2023. Bids will be opened on the same day at 15:00 Hours in the presence of tender opening committee and contractors' who wish to be participated. If office remains closed on bidding date for some reasons, this work will be carried out on the consecutive working day. This advertisement is also available on PPRA website at <a href="https://www.nbp.com.pk/TENDER">www.nbp.com.pk/TENDER</a>.

WING HEAD ENGINEERING WING (NORTH) NATIONAL BANK OF PAKISTAN G-5/1 BUILDING, ISLAMABAD PH: +92-51-9203117

## OPERATION AND MAINTENANCE OF HVAC PLANT / SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP, G-5/I BUILDING, ISLAMABAD

#### **SUMMARY**

O & M of above HVAC Plant/System for a Period of One Year.

1.

**CONTRACTOR (STAMP & SIGN)** 

BID FORM
(OFFER LETTER FROM BIDDER)

		(OTTER LETTER)	I KOW BIDDEK)	Dated:
Pr	ocuring Agency:	NATIONAL BANK	OF PAKISTAN	Dated.
ln۱	vited By:		neering Wing (Nor , G-5/1 Building, Is	•
Na	me of works:	PERATION AND MAI	NTENANCE OF HV	AC PLANT / SYSTEM
		OF DIRECT FIRE ABSO		
	<u>11</u>	NSTALLED AT NBP, G	-5/1 BUILDING ISL	<u>AMABAD</u>
Na	me of Bidder (in E	Block Capitals:)		
Bic	lder NTN No	Bidder PEC Regi	stration No	
Tel	l:	Mobile Nun	nber:	
Bic	lder Address:			
1.	contained and spec Bid, Bid Form, Bide Standard Forms an The breakup of our	ertake to examine and to e ified in conformity / compli ding Data, Schedules of p d are meant for in bidding <b>Bid Price</b> is given in Sch s of Pak Rs.	ance with the (Bidding prices, Terms and Co documents as mentic edule of prices (Bill o	g Documents) Invitation to anditions of Contract and aned above. f Quantities) and total Bid
3.	hereto form part of the As an assurance ob	ne said Documents and volthis Bid.  Soligation to this Bid, we have ak Rs.	e submitted a <b>Bid Se</b>	Il the bidding documents  curity (as per PPRA rules
4.	We agree to abide <b>Data</b> . We understa	of National Bank of Pakista by <b>Bid Validity Period</b> (and that bid validity period accepted at any time before	an along with our Bid. as per PPRA rules 26 starts from the date	) as specified in <b>Bidding</b> fixed for receiving of bids
5.	We undertake, if ou	or Bid is accepted to commed in the schedule within	ence the Works, we s	shall deliver and complete
6.	Unless and until a	Contract comes in exist constitute a Binding Memo		
7.	We clearly understaper PPRA Rule 33	and that National Bank of I prior to acceptance therec h it has received and not I	of. The Bank is not bo	ound to accept the lowest
8.	We do hereby dec	lare that this Bid has been ent with any other bidder of	en made without any	collusion, comparison of
Sig	nature			
Na	me (In Block Capitals	s):		
De	signation			
CN	IIC			Official Stamp / Seal
<u>WI</u>	TNESS:			
Sig	nature			
Na	me (In Block Capitals	s):		
CN	IIC			
Ad	dress:			

#### **INSTRUCTIONS TO BIDDERS / BIDDING DATA / CONTRACT DATA**

Procuring Agency: NATIONAL BANK OF PAKISTAN

Invited By: Wing Head, Engineering Wing (North), National

Bank of Pakistan, G-5/1 Building, Islamabad

Name of works: OPERATION AND MAINTENANCE OF HVAC PLANT/SYSTEM

OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON

INSTALLED AT NBP, G-5/1 BUILDING ISLAMABAD

Scope & Applicability : These bidding documents are applicable to the above-

mentioned works as a project.

**Scope of Tender Works** : OPERATION AND MAINTENANCE OF HVAC PLANT

/ SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP G-5/1

BUILDING ISLAMABAD.

**Bid Security/Earnest Money**: Payment Order/CDR amounting to 0.045Mn in favor of

National Bank of Pakistan enclosed with Sealed Bid. (In case of non- submission, Bid would be readily **rejected** 

at the time of Bid opening).

**Bid Submission Procedure**: Single Stage – Single envelope procedure as per rule 36 (a)

of Public Procurement Rules 2004. The bid shall comprise a single package containing two separate envelopes shall contain separately the financial proposal and the technical proposal duly stamped & signed by authorized person of bidder, related technical details / brochures and earnest money Pay order in Single Sealed Envelope marked as

"Original".

**Bid Submission Date &** 

**Time** : 30 November 2023; 14:30 HRS

**Bid Opening Date & Time :** 30 November 2023; 15:00 HRS

Bids Opening Place : Wing Head, Engineering Wing (North),

National Bank of Pakistan, G-5/1 Building,

Islamabad

**Bid validity period** : 120 days from the date of Opening of Bid.

**Currency of Payment**: Pak Rupees

O/M OF HVAC Plant : This term wherever used in Tender Documents will mean

Operation and Maintenance of Heating, Ventilation & Air-Conditioning Plant / System of Direct Fire Absorption Chillers Capacity 800 Ton installed at NBP, G-5/1 Building

Islamabad

**Evaluation Criteria**: Lowest Financial Evaluated Bid

Advance Payment : Nil

### OPERATION AND MAINTENANCE OF HVAC PLANT / SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP, G-5/I BUILDING, ISLAMABAD

#### **GENERAL TERMS AND CONDITIONS**

- 1. The contract shall be awarded for a period of One Year. The Contract will be initially for One Year, which can be extended further with mutual consent. The contract may be terminated by a written notice of the intention not to renew the agreement by either party with one month notice during the agreement period.
- 2. The employer will facilitate the working of the contractor by providing adequate facility particularly a suitable officer for the contractor's Engineer with a telephone extension from the existing intercom system during working hours for easy communication by the Contractor's Engineer with the concerned officials of National Bank of Pakistan.
- **3.** The Contractor will operate the plant/system providing effective Heating, Ventilation and Air-Conditioning in the building as follows: -

a) All working days From 8:00 AM to 6:00 PM

b) Temperature to be maintained. Temp Range (74°F/24°C TO 78°F/26°C)

c) Extra operation per month As per instruction of the employer

- **4. a)** The contractor will operate the plant/system on year-round basis. The cooling ventilation, heating would depend upon the weather conditions & decision in this regard will be at the direction of the employer.
  - **b)** Normally the cooling/heating cycle shall not be operated during November & February every year and contractor must complete the work of annual overhauling, maintenance, repair and servicing during this period so that the plant/system is in full working order by December & March.
- **5. a)** The contractor will submit a complete list of materials required for the operation and servicing of the plant/system and for the annual maintenance and overhauling, giving three months' time to the employer for their procurement for local material.
  - **b)** In case the Employer instructs the contractor to supply such items, the contractor will charge 10% as handling charges plus withholding tax set enforce to cover the procurement expenses. The bill of the contractor will be supported by the cash memos or bills of the suppliers for the purchased items.
- **6.** The contractor will be required to physically check the engineering stores of the employer to determine the availability of imported and indigenous spare parts. If any additional spare parts are required, the contractor will submit a list of the same to the employer giving one year's time for procurement of imported spare parts and four months' time for indigenous spare parts.
- **7. a)** The contractor will engage experienced and qualified staff for the operation servicing and maintenance of the plant/system who will work exclusively in the building and shall not be diverted to the contractor's other installation. The staff must remain at the site of work during the operation & maintenance of HVAC plant/system.
  - **b)** The contractor shall depute additional staff as required from his central workshop for carrying out the work of servicing and maintenance, particularly annual servicing, maintenance and overhauling without any extra cost.
  - c) The contractor shall arrange periodic site visits of his senior Engineer from his Head office to check operation of the plant/system and servicing, maintenance and overhauling work carried out by his staff. The contractor will submit the inspection report to the employer in first week of every quarter for previous quarter specially pointing out any deficiency/short-comings.
- **8.** The contractor will ensure that the spare parts etc. are replaced only when it is considered essential, maximum care would be exercised for economy and all efforts should be made

to repair the old part for its reuse. New part should only be substituted when the old part cannot be satisfactorily repaired.

- **9.** The observations for equipment operation and temperature record for working area of the building shall be noted at regular intervals in approved printed log sheets. One set of log sheets should be submitted to the employer representative the same day.
- 10. The contractor may carry out the servicing of the HVAC plant/system/system on Sunday. The contractor's supervisor Engineer shall inform the Employer's representative on Friday regarding the servicing work to be carried out on Sunday so that the Employer's representative can arrange necessary security and access for the contractor's staff.
- 11. The contractor must ensure the proper functioning of the plant/system. In case of unsatisfactory functioning or failure of the plant/system on account of negligence of contractor of which the Employer shall be the sole arbitrator/judge, the Employer shall have the right to terminate the agreement by giving a written notice of one month.
- 12. In case any equipment or parts of the plant/system are damaged or destroyed as a result of negligence of contractor, his agent or employees, the contractor shall be liable to pay for rectification and making good of all such damages or losses.
- **13.** The employer reserves the right to make deduction for the period of interrupted operation of the plant/system on pro-rata basis where the cause of interruption is attributable to the negligence of the contractor, of which the employer shall be the sole arbitrator /judge.
- **14.** For the execution of this contract, the Employer shall be represented by the Resident Engineer of the Employer (herein nominated by the Employer for this purpose and notified in writing to the Contractor for operation & maintenance of HVAC plant/system.
- **15.** The Contractor must ensure to good behavior by his staff and the Contractor's supervisor Engineer should liaison with and follow the instruction of the Employer's representative, particularly regarding the entry of Contractor's staff to the building occupied areas for operation & maintenance of HVAC plant/system.
- **16.** The Employer representative may instruct the contractor's supervisor Engineer to operate the plant/system (i) beyond normal hour on working day or (ii) on a Sunday or Public Holiday if required by giving notice two day before the Holiday, Contractor supervising Engineer will take certificate in writing from the Employer's representative regarding the date and period of the additional operation.
- **17.** The Contractor should submit his bill to the Employer's representative during 1<sup>st</sup> week of every month for the work carried out during the preceding month, payment shall normally be made within 21 days of the submission of the bill.

### OPERATION AND MAINTENANCE OF HVAC PLANT / SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP, G-5/I BUILDING, ISLAMABAD

#### SCHEDULE NO.1

#### **SCOPE OF WORK**

- 1. The Contractor shall be responsible for the operation of complete heating, ventilation & air-conditioning plant/system, complete servicing and maintenance of all equipment, controls, components and accessories including minor repair, annual overhauling and servicing. Major repairs, when required are not included in the scope of works.
- **2.** The employer shall be responsible for the followings;
  - a) Electricity and water supply.
  - b) Spares and materials required for operation, maintenance, servicing, minor repairs and overhauling excluding misc. items listed in para 3 c.
  - c) Water treatment chemicals, refrigerants, and any special lubricants or oils.
  - d) Suitable office for contractor's supervisor Engineer within or close to the central plant/system room with telephone extension from the existing Building intercom system for easy communication with the concerned officials of NBP.
- **3.** The Contractor shall be responsible for providing following staff & services.
  - a) Supervisor, Associate Engineer, Mechanic fitter, Electrician/helper tools and instruments required for operation, regular and annual servicing, overhauling, maintenance and minor repairs.
  - b) To keep the plant/system room adjoining passages terrace clean and neat, cleaning to be done every day.
  - c) Supply of Misc. items required for work such as cotton waste, cleaning agents and cloth, chemicals & lubricants, grease and floor polish.
- **4.** The Contractor shall ensure that the Heating, Ventilation & Air-Conditioning Plant/system is operated, maintained and serviced efficiently to avoid breakdown during normal operation. The contractor shall also ensure economical consumption of the material and spare parts supplied by the Employer.
- 5. The Contractor shall be responsible for;
  - a) The temperature on each floor at different locations shall be recorded at least twice daily.
  - b) The equipment operational observations shall be recorded at suitable intervals.
  - c) All readings shall be recorded in approved printed log sheets prepared in duplicate. One set would be supplied to the Employer's representative every day.
- **6.** The Contractor shall be responsible for;
  - a) The supervisor Engineer of contractor shall regularly submit a monthly report in triplicate to the Employer's representative by 5<sup>th</sup> day of each month regarding overall performance of the complete plant/system during the preceding month and pinpoint any action to be taken by the Employer.
  - b) The Contractor will carry out general overhauling of Heating, Ventilation & Air-Conditioning plant/system once in the month and as when require for smooth operation of plant/system.
  - c) The contractor shall arrange periodic visit (at least once every quarter) from his Head office to check the operation of the complete HVAC plant/system and servicing, maintenance and overhauling works carried out by the Contractor's staff. The Contractor will submit the inspection report to the employer in the first week of every quarter for the preceding quarter.
- 7. The contractor shall submit an estimate to the employer for approval before carrying out any major repair which become necessary in due course but not due to any negligence or default of the contractor, his agents of which the employer shall be the sole judge. The estimate shall be submitted expeditiously so as not to disrupt the plant/system operation. The contractor shall undertake the work on approval of estimate by Employer.

- **8.** The Contractor shall be responsible for:
  - a. Regular and effective chemical treatment of water for condensing, chilled water system by taking samples and testing and recording the result daily.
  - b. Cleaning, removals and prefixing of all air devices, painting of all devices is excluded which will be considered a major repair work.
  - c. Removal & prefixing of false ceiling tiles as required by the contractor for carrying out his work. The contractor shall be responsible for any damage to false ceiling framing and tiles.
- **9.** The work routine servicing and maintenance as required must be completed by the contractor's staff every day.
- **10.** The O&M work is briefly detailed in para. 11, 12 & 13 for referenced only without any limitation.

#### 11. PLANT/SYSTEM OPERATION.

- a) Checking the working of all electrical and mechanical components of the equipment.
- b) Dosing of chemicals for treatment of condensing and water and testing of water samples.
- c) Maintenance of daily operation log sheets.
- d) Any servicing of running repair required during the operation of the plant/system.

#### 12. Weekly/Biweekly/Monthly servicing, and Maintenance of Plant/system.

- a) Washing and cleaning of Air-filters.
- b) Flushing and cleaning of strainers of water system.
- c) Servicing of automatic and safety control of equipment and Air-Conditioning systems.
- d) Checking of all lubricants levels and cleaning the same when required for all equipment components.
- e) Checking of belt driven equipment and adjustment of belt and alignment.
- f) Checking of water levels and level controls valves.
- g) Change of parts due to normal wear & tear when necessary.
- h) Adjustment and lubrication/ greasing of bearings and other components of equipments.
- i) Checking and adjustment of all pressure and safety devices.

#### 13. Annual Maintenance and overhauling

- **13.1** The work to be carried out between 1<sup>st</sup> to 15<sup>th</sup> of November & 15<sup>th</sup> to 28<sup>th</sup> February under the supervision of Sr. Resident Engineer. Parts to be changed where necessary instructions given in the manufacturers manuals to be followed. Record of various checks and test to be maintained for the future reference.
- **13.2** Automatic and safety controls.

#### 13.3 a) Servicing of all water Pumps.

b) Adjustment of glands and bearings.

#### 13.4General Overhauling

- a) Flushing and cleaning of Condenser tubes.
- b) Checking and adjustment of dampers.
- c) Checking and adjustment of all bearing and belts.

#### **13.5** FANS

- a) Cleaning of fans
- b) Checking and adjustment of bearings.

#### **13.6** Air-Filters

Cleaning and repairing of Air-Filters.

#### **13.7** Cooling Towers

- a) Servicing, cooling towers motors, overhauling of gears and greasing of bearing.
- b) Cleaning of PVC fill with light chemical by taking it outside the cooling towers.
- c) Repairing of leakage of cooling tower with fiber, cloth, cobalt and chemical etc.
- d) Cleaning of Pipes, Sprinkles head etc.

#### **13.8** Automatic Controls

Checking of calibration of automatic temperature, humidity and level controls.

#### 13.9 Temperature Recording

Checking of calibration of temperature sensing devices.

#### **13.10** Electric Motor and Starters.

- a) Cleaning and checking of all components.
- b) Tightening of wiring connections.
- c) Cleaning and adjustment of connectors.
- d) Checking of earthling.
- e) Checking of motor winding insulation with Megger.

#### **13.11** Electrical Control boards and Electric systems.

- a) Checking and servicing of all MCCBs, disconnected switches fuses, connectors, relays, overload cutouts and safety devices.
- b) Tightening of wiring connections.
- c) Checking of wiring insulation.
- d) Checking of earthling.

#### **13.12** Air-Distributing system

- a) Cleaning of air devices, painting is excluded.
- b) Repair of exposed duct, duct insulation, jacketing and covering.

#### 13.13 Piping System

- a) Cleaning and flushing of all piping system including chemical cleaning when required.
- b) Servicing of all valves, specialties, strainers, seats.
- c) Repair of insulation, and covering of all insulation.

#### **13.14** Painting

- a) Painting of all equipment's, exposed ducting and piping. If the original paint has been scratched or has deteriorated.
- b) Painting of air-devices is excluded.

#### **SCHEDULE NO.2**

#### **STAFF STRENGTH**

#### A. ASSOCIATE ENGINEER 01 NO.

Associate Engineer having three (3) year diploma in HVAC / Mechanical or Air-Conditioning with 05 years relevant HVAC experience in reputed firm.

#### B. **OPERATOR/MECHANIC.** 01 NO.

Matric, with five (5) years experience of maintenance of electrical panel of HVAC equipment in reputed firm.

#### C. <u>ELECTRICIAN.</u> 01 NO.

Matric with five (5) years experience of maintenance of Electrical panel of HVAC equipment in reputed firm.

#### D. PLUMBER/PIPE FITTER 01 NO.

Having three (3) years experience of HVAC experience.

- E. An experienced Engineer from firm's H.O shall inspect the plant/system after **every 60-days**. The Engineer shall have sufficient experience in direct fire absorption system. He shall report his findings to the Bank after each visit.
- **F.** In case of any major breakdown, the contractor shall depute his **Senior Engineer** from company H.O for rectification purpose.
- **G.** No TA/DA shall be paid by the Bank on account of obligations mentioned at E & F above.

### NATIONAL BANK OF PAKSITAN BOQ

# OPERATION AND MAINTENANCE OF HVAC PLANT/SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP, G-5/I BUILDING, ISLAMABAD

		Contract	Rate	Rate	
Sr#	Description	duration /	In figure	In word	Total
		Months	P. Month	P. Month	Amount
01.	Operations and maintenance of HVAC				
	plant/system capacity of 800 tons				
	containing direct fire absorption chillers				
	and on monthly basis containing following				
	equipment's / parts.				
	<ol> <li>Chillers Capacity nominal</li> </ol>				
	400 ton each 02 Nos.				
	2. Cooling tower 02 Nos.				
	<ol><li>Electrical panels Lot</li></ol>				
	4. Chilled water pump 03 Nos				
	5. Centrifugal pumps 03 Nos				
	6. Air-handling units 14 Nos.				
	7. Pneumatic Accessories Lot				
	8. Electrical controls Lot				
	9. Thermodynamic controls Lot				
	10. Piping System Lot				
	The H.V.A.C plant/system comprises two				
	direct fire absorption chillers brand				
	SANYO, air-handling units, control panel,				
	electrical controls & panels, cabling,				
	piping and HVAC ducting network with				
	controls, supply and return air grills &				
	diffusers along with all accessories and				
	components of heating, ventilation and				
	air-conditioning system which require				
	successful, smooth and trouble-free				
	operation for maintaining comfortable				
	inside temperature of the building within				
	range ( <b>74</b> ° <b>F /24</b> ° <b>C - 78</b> ° <b>F /26</b> ° <b>C)</b> . at each				
	block of all floors. The salient features,				
	technical specifications and general terms				
	& conditions for operation of HVAC				
	system are detailed in				
	Annexure A.				
	The rates should include all applicable				
	taxes by the Federal / Provincial	12 Months			
	Government.				
	(Note: The Contract will be initially for One Year, which can be extended further with mutual consent)				
	winer can be extended further with flutual collsellt)			Total	
				Amount	
Total	amount in words: Rupees:	•			•

For Bidder (STAMP & SIGN)

#### ANNEXURE – A

#### OPERATION AND MAINTENANCE OF HVAC PLANT/SYSTEM OF DIRECT FIRE ABSORPTION CHILLERS CAPACITY 800 TON INSTALLED AT NBP, G-5/I BUILDING, ISLAMABAD

Sr#	Description	QTY
01.	Chillers Capacity nominal 400 ton each SANYO direct fire chillers with fire burner, electrical control, electrical panels, mechanical system, generator, steam lines, chilled and condenser pump lines, steam trap controllers.	02 Nos
02.	Cooling Tower Fans, motors, PVC fills, valves, sump, piping, supports etc.	02 Nos
03.	Electrical panels Breakers, magnetic contactors, overload relays, fuses, electric wiring, cabling network, main breaker indication lights, bus bars etc.	Lot
04.	Components of chilled water pumps, Three phase electric motor, casing, shafts, bearing, seals, impeller, locking, gas kit, coupling, gate globe valves, strainers, check valves, expansion joint, foundation with water pumps along with allied components and accessories.	03 Nos
05.	Centrifugal condenser pump  Three phase electric motor, casing, shafts, bearing, seals, impeller, locking, gas kit, coupling, gate globe valves, strainers, check valves, expansion joint, foundation with water pumps along with allied components and accessories.	03 Nos
06.	Air-Handling Units Blower, belt, casing, motor, coil, fins, drains, ducts, liner etc.	14 Nos
07.	Maintenance of electro-mechanical equipment require for smooth and trouble-free operation of A.C System which include piping and G.I piping network, G.I and M.S lines and fitting ducts dampers fire dampers.	Lot
08.	Electrical and thermodynamic auto controls etc.	Lot
09.	Pneumatic system with manual and auto controls etc.	Lot

For Bidder (STAMP & SIGN)